# Date created, 10/03/2017 - Subject to change. © Belimo Aircontrols (USA), Inc.

# **P2200S-403,2", Electronic Pressure Independent Valve** Stainless Steel Ball and Stem, Female NPT Ends







WARRAN

abulant Data	
chnical Data rvice	chilled or hot water, up to 60% glycol max
i vice	(open loop/steam not allowed)
ow Characteristic	equal percentage or linear
ze [mm]	2" [50]
id Fitting	NPT female ends
ody	forged brass, nickel plated
ensor Housing	forged brass, nickel plated
ill	stainless steel
em	stainless steel
****	0141111000 01001
at	Teflon® PTFE
at O-ring	EPDM
naracterized Disc	TEFZEL® or stainless steel
ody Pressure Rating [psi]	360
edia Temperature Range	14°F to 250°F [-10°C to 120°C]
/ater)	
fferential Pressure Range	5 to 50 psid, 1 to 50 psid (with flow
	reduction. See chart.), or 8 to 50 psid (with
ose-Off Pressure	flow increase. See chart.) 200 psi
	•
let Length to Meet Specified	5X nominal pipe size (NPS)
easurement Accuracy nbient Humidity	<95% RH non-condensing
ow Measurement Tolerance	±2%*
ow Control Tolerance	+5%
	20 / 0
ow Measurement Repeatability	±0.5%
ensor Technology	ultrasonic with glycol and temperature compensation
ingeability	100:1
ower Supply for the Flow Sensor	100.1
eight	sensor is powered by the actuator
GIYIII I	sensor is powered by the actuator
PM	

<sup>\*</sup>All flow tolerances are at 68°F (20°C) & water.

### **Application**

Water-side control of heating and cooling systems for AHUs and water coils. Equal Percentage/ Linear: heating and cooling applications.

# Operation


The Electronic Pressure Independent Control Valve is a two-way valve that maintains constant flow regardless of pressure variations in the system.

### **Product Features**

Provides constant flow regardless of pressure variations in the system.  $\label{eq:maximizes} \mbox{ Maximizes chiller P, preventing energizing additional chillers due to low \ T.}$ Simplified valve sizing and selection, no Cv calculations required.

### **Suitable Actuators**


Gartable Hetaatere				
	Non-Spring	Electronic Fail-Safe		
P2200S-403	ARB(X)	AKRX		



Α	В	C	D	Е	F
17.04"	11.18"	6.89" [175]	5.59" [142]	1.73	" [44]
[433]	[284]				



# P2200S-403,2", Electronic Pressure Independent Valve Stainless Steel Ball and Stem, Female NPT Ends



Α	В	С	D	Е	F
18.23"	11.18"	9.04" [229]	7.79" [198]	1.89	" [48]
[463]	[284]				





Technical Data	
Power Supply	24 VAC ± 20%, 50/60 Hz, 24 VDC ± 10%
Power Consumption Running	4.5 W
Transformer Sizing	7 VA (class 2 power source)
Electrical Connection	3ft [1m], 18 GA plenum cable with 1/2" conduit
	connector
Overload Protection	electronic thoughout 0° to 90° rotation
Operating Range Y	2 to 10 VDC (default) VDC variable
Input Impedance	100 kΩ (0.1 mA), 500 Ω
Feedback Output U	2 to 10 VDC (default) VDC variable
Angle of Rotation	90°
Torque	180 in-lbs [20 Nm] minimum
Direction of Rotation (Motor)	reversible with pc tool
Position Indication	integrated into handle
Manual Override	external push button
Running Time (Motor)	90 sec
Ambient Humidity	5 to 95% RH non condensing (EN 60730-1)
Ambient Temperature Range	-22°F to 122°F [-30°C to 50°C]
Storage Temperature Range	-40°F to 176°F [-40°C to 80°C]
Housing	NEMA 2, IP54
Housing Material	UL94-5VA
Agency Listings†	cULus acc. to UL60730-1A/-2-14, CAN/CSA
	E60730-1:02, CE acc. to 2004/108/EC and
	2006/95/EC
Noise Level (Motor)	max. 45 dB (A)
Servicing	maintenance free
Quality Standard	ISO 9001
Weight	2.6 lb [1.2 kg]

†Rated Impulse Voltage 800V, Type action 1, Control Pollution Degree 3.







### Wiring Diagrams



### X INSTALLATION NOTES



Provide overload protection and disconnect as required.



Actuators may be connected in parallel. Power consumption and input impedance must be observed.



Actuators may also be powered by 24 VDC.



Actuators with plenum cable do not have numbers; use color codes instead.



IN4004 or IN4007 diode required



Meets cULus requirements without the need of an electrical ground connection.



# WARNING! LIVE ELECTRICAL COMPONENTS!

During installation, testing, servicing and troubleshooting of this product, it may be necessary to work with live electrical components. Have a qualified licensed electrician or other individual who has been properly trained in handling live electrical components perform these tasks. Failure to follow all electrical safety precautions when exposed to live electrical components could result in death or serious injury.

