

# VG1000 Series Flanged Ball Valves

## Installation Instructions

VG12A5xx, VG18A5xx

Part No. 14-1352-6, Rev. E

Issued April 3, 2014

Supersedes August 28, 2009

### Applications

The VG1000 Series Flanged Ball Valves are designed to regulate hot and chilled water, 50/50 glycol solutions, and 25 psig steam in Heating, Ventilating, and Air Conditioning (HVAC) systems

**IMPORTANT:** The VG1000 Series Flanged Ball Valve is intended to control saturated steam, hot water, and chilled water flow under normal operating conditions. Where failure or malfunction of the ball valve could lead to personal injury or property damage to the controlled equipment or other property, additional precautions must be designed into the control system. Incorporate and maintain other devices, such as supervisory or alarm systems or safety or limit controls, intended to warn of or protect against failure or malfunction of the ball valve.

**IMPORTANT:** Le VG1000 Series Flanged Ball Valve est destiné à réguler un débit saturated steam, hot water, and chilled water dans des conditions normales de fonctionnement. Lorsqu'une défaillance ou un dysfonctionnement du ball valve risque de provoquer des blessures ou d'endommager l'équipement contrôlé ou un autre équipement, la conception du système de contrôle doit intégrer des dispositifs de protection supplémentaires. Veiller dans ce cas à intégrer de façon permanente d'autres dispositifs, tels que des systèmes de supervision ou d'alarme, ou des dispositifs de sécurité ou de limitation, ayant une fonction d'avertissement ou de protection en cas de défaillance ou de dysfonctionnement du ball valve.

### Installation

Install the VG1000 Series Flanged Ball Valves with the actuator at or above the centerline of the horizontal piping, as shown in Figure 1.

**IMPORTANT:** In steam applications, install the valve with the stem horizontal to the piping. Failure to follow these guidelines may shorten the life of the actuator.

To minimize heat transfer in steam applications, wrap the valve and piping with insulation. Allow at least 4 in. (102 mm) of clearance from the top of the shaft to remove the actuator (as noted in Table 1).

When mounting the actuator in the field and before installing the actuator, use an adjustable wrench to manually rotate the valve stem several times. This rotation breaks the torque that may have built up during long-term storage.


**IMPORTANT:** Do not attempt to manually rotate the drive shaft while the actuator is installed without first releasing the actuator gears. Manually rotating the drive shaft without releasing the actuator gears may result in permanent damage to the actuator.

**IMPORTANT:** Take care to prevent foreign material such as weld slag, thread burrs, metal chips, and scale from entering the piping system. This debris can damage or severely impede the operation of the valve by embedding itself in the seats, scoring the valve, and ultimately resulting in seat leakage. If the debris becomes embedded in the seats, subsequent flushing and filtering of the piping system with the valve installed does not remedy the problem.

For detailed installation information about using specific equipment, refer to the appropriate documentation from the following list.

- *M9108, M9116, M9124, and M9132 Series Electric Non-Spring Return Actuators Installation Instructions (Part No. 34-636-399)*
- *M9220-AGx-3 Series Floating Electric Spring Return Actuators Installation Instructions (Part No. 34-636-1689)*
- *M9220-Bxx-3 Series On/Off Electric Spring Return Actuators Installation Instructions (Part No. 34-636-1239)*
- *M9220-GGx-3 Series Proportional Electric Spring Return Actuators Installation Instructions (Part No. 34-636-1697)*


- *M9000-330 and M9000-340 Series Weather Shield Enclosures Installation Instructions (Part No. 14-1330-26)*
- *M9000-51x Series Valve Linkage Kits Installation Instructions (Part No. 14-1201-13)*




**Figure 1: Recommended Mounting Positions for Non-Steam Applications**

## Dimensions

See Figure 2 for VG12A5xx Two-Way Series Flanged Ball Valves with M9124 Series Actuators dimensions. See Figure 3 for VG18A5xx Three-Way Series Flanged Ball Valves with M9124 Series Actuators dimensions. See Table 1 for specific model dimensions.




**Figure 2: M9124 Actuated VG12A5xx Two-Way Series Ball Valves, in. (mm)**




**Figure 3: M9124 Actuated VG18A5xx Three-Way Series Ball Valves**

See Figure 4 for VG12A5xx Two-Way Series Flanged Ball Valves with M9220 Series Actuators dimensions. See Figure 5 for VG18A5xx Three-Way Series Flanged Ball Valves with M9220 Series Actuators dimensions. See Table 1 for specific model dimensions.



**Figure 4: M9220 Actuated VG12A5xx Two-Way Series Ball Valves, in. (mm)**




**Figure 5: M9220 Actuated VG18A5xx Three-Way Series Ball Valves**

**Table 1: VG1xA5xx Series Ball Valves Dimensions, in. (mm)**


Valve Size, in. (DN)	A	B	C	D		F	G (Bolt Circle)	H	Number of Bolts
				M9124 <sup>1</sup>	M9220 <sup>1</sup>				
2-1/2 (DN65)	3.50 (89)	5.71 (145)	11.42 (290)	8.89 (226)	9.64 (245)	5.87 (149)	5.50 (139)	0.75 (19.1)	4
3 (DN80)	3.75 (95)	6.10 (155)	12.20 (310)			6.26 (159)	6.00 (152)		4
4 (DN100)	4.50 (114)	6.89 (175)	13.77 (350)			7.05 (179)	7.50 (191)		8

1. Allow a minimum of 4 in. clearance above the shaft to remove the actuator.


See Figure 6 for VG12A5xx Two-Way Series Flanged Ball Valves with the M9124 Series Non-Spring Return Actuators dimensions. See Figure 7 for VG18A5xx Three-Way Series Flanged Ball Valves with the M9124 Series Non-Spring Return Actuators dimensions. Each drawing includes dimensions for the field-installed M9000-330 Weathershield. See Table 2 for specific model dimensions.




**Figure 6: Actuated VG12A5xx Two-Way Series Ball Valves with M9000-330 Weathershield Dimensions, in. (mm)**



**Figure 8: Actuated VG12A5xx Two-Way Series Ball Valves with M9000-340 Weathershield Dimensions, in. (mm)**



**Figure 7: Actuated VG18A5xx Three-Way Series Ball Valves with M9000-330 Weathershield**



**Figure 9: Actuated VG18A5xx Three-Way Series Ball Valves with M9000-340 Weathershield**

**Table 2: VG1xA5xx Series Ball Valves Dimensions, in. (mm)**

Valve Size, in. (DN)	A	B	C	D		F	G (Bolt Circle)	H	Number of Bolts
				M9124 <sup>1</sup>	M9220 <sup>1</sup>				
2-1/2 (DN65)	3.50 (89)	5.71 (145)	11.42 (290)	8.89 (226)	9.64 (245)	5.87 (149)	5.50 (139)	0.75 (19.1)	4
3 (DN80)	3.75 (95)	6.10 (155)	12.20 (310)			6.26 (159)	6.00 (152)		4
4 (DN100)	4.50 (114)	6.89 (175)	13.77 (350)			7.05 (179)	7.50 (191)		8

1. Allow a minimum of 4 in. clearance above the shaft to remove the actuator.

## Mounting

### Location Considerations


**IMPORTANT:** Protect the actuator from dripping water, condensation, and other moisture. Water or moisture could result in an electrical short, which may damage or affect the operation of the actuator.

**IMPORTANT:** Do not cover the actuator with thermal insulating material. High ambient temperatures may damage the actuator, and a hot water pipe, a steam pipe, or other heat source may overheat it.


### Piping

Be sure to wire the input lines to the electric actuator correctly for the valve to move in the proper direction. See Figure 10 for typical two- and three-way piping configurations.

**IMPORTANT:** Use copper conductors only. Make all wiring connections in accordance with local, national, and regional regulations. Do not exceed the actuator's electrical ratings.



Typical Two-Way Ball Valve Application



Typical Three-Way Ball Valve Application

FIG: VG1000pipapp

**Figure 10: Typical VG1000 Series Flanged Ball Valves Piping Application**


**Note:** Mount the valve downstream from the coil to minimize heat transfer to the actuator.

## Setup and Adjustments


Port A has the flow characterizing disk. Connect Port A to the outlet from the coil. On three-way models, use Port B as the bypass port.

Two-way VG1000 Series Ball Valves are fully open when the electric actuator is fully Counterclockwise (CCW) and fully closed when the electric actuator is fully Clockwise (CW).

For three-way valves, the Coil Port A and Common Port AB are fully open when the electric actuator is fully CCW, as shown in Figure 11. The Bypass Port B and Common Port AB are fully open when the actuator is fully CW, as shown in Figure 12.



**Figure 11: VG18A5 Series Three-Way Ball Valve (Coil Port A Open to Common Port AB)**



**Figure 12: VG18A5 Series Three-Way Ball Valve (Bypass Port B Open to Common Port AB)**

For non-spring return and spring-to-open proportional control models in the Direct Acting (DA) mode, a minimum control signal drives the electric actuator to the fully CCW position while a maximum control signal drives the electric actuator in the fully CW position.

For spring-to-close proportional control models in the DA mode, a minimum control signal drives the electric actuator to the fully CW position, while a maximum control signal drives the electric actuator to the fully CCW position.

## Troubleshooting

### ***Servicing the Actuator or Piping System***

When servicing the electric actuator or the piping system:

- disconnect the power supply to the actuator



#### **WARNING: Risk of Electric Shock.**

Disconnect or isolate all power supplies before making electrical connections. More than one disconnection or isolation may be required to completely de-energize equipment. Contact with components carrying hazardous voltage can cause electric shock and may result in severe personal injury or death.

#### **AVERTISSEMENT : Risque de décharge électrique.**

Débrancher ou isoler toute alimentation avant de réaliser un raccordement électrique. Plusieurs isolations et débranchements sont peut-être nécessaires pour -couper entièrement l'alimentation de l'équipement. Tout contact avec des composants porteurs de tensions dangereuses risque d'entraîner une décharge électrique et de provoquer des blessures graves, voire mortelles.

- relieve the pressure in the piping system



#### **CAUTION: Risk of Property Damage.**

Do not apply power to the system before checking all wiring connections. Short circuited or improperly connected wires may result in permanent damage to the equipment.

#### **MISE EN GARDE : Risque de dégâts matériels.**

Ne pas mettre le système sous tension avant d'avoir vérifié tous les raccords de câblage. Des fils formant un court-circuit ou connectés de façon incorrecte risquent d'endommager irrémédiablement l'équipement.

## Repair Information

If the VG1000 Series Flanged Ball Valve fails to operate within its specifications, replace the unit. For a replacement valve, contact the nearest Johnson Controls® representative.

## Technical Specifications

### VG1000 Series Flanged Ball Valves

<b>Service<sup>1</sup></b>		Hot Water, Chilled Water, 50/50 Glycol Solutions, and 25 psig (172 kPa) Saturated Steam for HVAC Systems
<b>Valve Fluid Temperature Limits</b>		0 to 284°F (-18 to 140°C)
<b>Valve Body Pressure/Temperature Rating</b>	<b>Water</b>	ASME Class 150 250 psi at -20 to 100°F (29 to 38°C) 235 psi at: 200°F (93°C) 218 psi at: 284°F (140°C)
	<b>Steam</b>	25 psig (172 kPa) Saturated Steam for HVAC Systems
<b>Maximum Closeoff Pressure</b>	<b>Two-Way</b>	100 psi (689 kPa)
	<b>Three-Way</b>	50 psi (345 kPa)
<b>Maximum Recommended Operating Pressure Drop</b>		30 psi (207 kPa) for quiet service
<b>Flow Characteristics</b>	<b>Two-Way</b>	Equal Percentage
	<b>Three-Way</b>	Equal Percentage Flow Characteristics of In-line Port or Linear Percentage Flow Characteristics of Angle Port
<b>Rangeability<sup>2</sup></b>		Greater than 500:1
<b>Leakage</b>	<b>Two- or Three-Way</b>	0.01% of Maximum Flow, Control Port, ANSI/FCI 70-2, Class 4
	<b>Three-Way</b>	1% of Maximum Flow, Bypass Port
<b>End Connections</b>		ASME Class 150 Flange
<b>Minimum Ambient Operating Temperature</b>	<b>-4°F (-20°C)</b>	M9124 Series Non-Spring Return Actuators
	<b>-40°F (-40°C)</b>	M9220 Series Spring Return Actuators
<b>Maximum Ambient Operating Temperature<sup>3</sup></b>	<b>122°F (50°C)</b>	M9124 Series Non-Spring Return Actuators
	<b>131°F (55°C)</b>	M9220 Series Spring Return Actuators
<b>Materials</b>	<b>Body</b>	Brass
	<b>Flanges</b>	Ductile Iron
	<b>Ball</b>	300 Series Stainless Steel
	<b>Stem</b>	300 Series Stainless Steel

1. Refer to VDI 2035 Standard for proper water treatment.
2. Rangeability is defined as the ratio of maximum controllable flow to minimum controllable flow.
3. In steam applications, install the valve with the stem horizontal to the piping, and wrap the valve and piping with insulation.

*The performance specifications are nominal and conform to acceptable industry standards. For application at conditions beyond these specifications, consult the local Johnson Controls office. Johnson Controls, Inc. shall not be liable for damages resulting from misapplication or misuse of its products.*



**Building Efficiency**

507 E. Michigan Street, Milwaukee, WI 53202

*Metasys® and Johnson Controls® are registered trademarks of Johnson Controls, Inc. All other marks herein are the marks of their respective owners. © 2014 Johnson Controls, Inc.*